

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0981:106

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Greenheck Fan, PO Box 410, Schofield WI 54476-0410
Contact: *Marty Gissel (715) 355-6611 Fax (715) 355-3954

DESIGN: Models CFSD-22, CFSD-23, CFSD-33, SSCFSD-22, SSCFSD-23, *CFSD-211, *CFSD-212, *CFSD-311, and *CFSD-312 multi-blade type fire dampers. Unit constructed of No. 16 Ga. galvanized or stainless steel blade and No. 20 Ga. galvanized or stainless steel frame. The sizes of the dampers are as follow:

<u>Width, In.</u>		<u>Height, In.</u>	
Minimum	Maximum	Minimum	Maximum
6	24	6	24

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 1 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as 1-Hr fire dampers. Intended for horizontal installation only.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers. (See Listing No. 3230-0981:105)

*Rev. 05-27-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 10, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager